

Progress Meeting

So. Thomaston, WIN 20485.00

Sept. 19, 2017

Attendee's

C. Thompson, MDOT

S. Rogers, Kleinfelder

T. Clark, Reed-Reed

P. Garrett, Reed-Reed

W. Reinhardt, GC Hall

V. Bale, GC Hall

Progress for the last week:

Labor/wage rate board set up with correct postings

Completed installing the detour signs and covered

Set up portable message boards and activated

Sta. 209+75 to 210+30+- Started excavating and installing heavy rip rap slopes

Installed 18" option III pipe plus extended pipe and tied in cellar drain with test station (see mod 2)

Installed CB, top to be brought up at a later date

Striped Westbrook St. as requested by town

Sta. 208+00 to 209+30+- lt., Box cut shoulders to subgrade and placed ASCG

Reed continues to mobilize

Expected work for the next week

Continue to mobilize to site

Continue installing rip rap

Remove fence at sta. 209+00 rt.

Schedule

14-day notice waterway passage and 10-day public notice local paper has been sent out.

Submittals

Test jack for rock dowels has been submitted

Traffic, SEWPCP, Demo plan and QC for 502 approved.

HMA QC plan still needs to be resubmitted

Precast

Possibly cast first beam yesterday

28-day test results show strength was not met on first pre-cast piece. Reed's field cure test results indicate strengths have been met. Reed will submit tests for review

Detour/Traffic

Reed will move one portable message board to the end of Chapel St.

Dredge spoils

Dredge spoils will be brought to Hartland special waste facility. GC Hall will contact them and arrange for the necessary testing/trucking

Misc.

I will process an estimate this week

The DOT will need testing equipment

ASCG and granular borrow, underwater backfill samples have been taken and sent to Bangor Lab.

Fence will be removed. Landowner does not want fence put back up.

The church sign on Chapel St. will need to be moved back to the new RoW

MHPC still scheduled Wed. 9-27

The next weekly meeting will be held on-site at MDOT's field office located in the basement of the Methodist Church on Chapel St. on Tuesday Sept. 26 at 11 am.

Any authorized persons who take exception to any statement in this report must notify the Resident in writing within five work days from receipt of this report, stating in detail the comment, correction or omission. Otherwise, this report shall stand as written.

Prepared by: C. Thompson, MDOT Resident Inspector